

CITY OF SPRINGFIELD  
INTER-OFFICE MEMORANDUM

ATTENTION OF \_\_\_\_\_ FILE \_\_\_\_\_

DATE \_\_\_\_\_ February 3, 1984

DEPARTMENT \_\_\_\_\_

Taylor Petroleum  
Subject - Fuel Tank Testing

Please find attached the results of Petro-Tite testing for the fuel storage tanks at Taylor Petroleum Co., 1201 W. Sunshine. Testing was conducted during the period January 14 to January 17, 1984. Test results are as follows:

Unlead tank = -.033  
Premium unlead = -.023  
Regular = +.001

Testing was conducted by Montgomery Metal Craft, Inc., Route 5, Box 355, Springfield, Missouri and indicate that these tanks do not exceed the standard of .050.

cc: Karen Chandler, Water Pollution Control ITspector II

1201 W. Sunshine  
SIGNED \_\_\_\_\_  
Bob Corson  
Water Pollution Control Ins. III  
Surveillance & Enforcement